



SUB-BASE DRAINAGE DITCH SECTION

SUB-SURFACE DRAINAGE DITCH SECTION




OUTLET DITCH SECTION

5" CONCRETE GUTTER FOR UNDERDRAIN OUTLET



NOTE: UNDERDRAIN TO BE LAID ON A MINIMUM OF 0.5% GRADE UNLESS OTHERWISE DIRECTED.

*NOTE 'A':WHERE UNDERDRAIN IS OUTLETTED
INTO AN INLET. OR WHERE ANY
OTHER UNUSUAL CONDITIONS PREVAIL.
THESE DIMENSIONS MAY BE VARIED
AS DIRECTED.



TOE WALL

ELEVATION-UNDERDRAIN OUTLET

APPROVED

APPROVED

APPROVED

DIRECTOR - OFFICE OF HIGHWAY DEVELOPMENT

APPROVAL • SHA
REVISIONS
APPROVAL • SHA
HIGHWAY ADMINISTRATION
APPROVAL 3-6-86
APPROVAL 4-14-86
REVISED
REVISED
REVISED
REVISED
REVISED
REVISED
REVISED

Maryland Department of Transportation STATE HIGHWAY ADMINISTRATION

STANDARDS FOR HIGHWAYS AND INCIDENTAL STRUCTURES

STANDARD UNDERDRAINS

STANDARD NO. MD 387.01